Electron Laser interaction System consists of Relativistic electron beam Magnetic field Laser beam Following section describes interaction of the electron beam with either magnetic field, laser beam or both

References: *Classical Electrodynamics*, Jackson, Ch. 9, 12, 14, *Free Electron Lasers*, C. H. Brau, Ch.1, 2 *High energy free electron laser accelerator*, E. D. Courant, C. Pellegrini, W. Zakowicz, Phys. Rev A 32(1985) 28 January 10 (1985) 28 January 10 (1





FIG. 1. Schematic view of IFEL accelerator.

Let us consider a system where relativistic electrons are moving along a magnetic wiggler in the filed of a laser. Let us further assume that the Poynting vector of the laser, the electron propagation direction, and the wiggler axis are parallel. The Lorentz equation of motion of the electron, including the force of radiation reaction, F_{reac} , can be written as

$$m\frac{d(\gamma \vec{v})}{dt} = e\left[\vec{E}_l + \frac{\vec{v}}{c} \times \left(\vec{B}_l + \vec{B}_w\right)\right] + \vec{F}_{reac}$$

 $\beta = v / c$

Is the electric field of the laser,

 \vec{E}_{i}

 $\gamma = (1 - \beta^2)^{-1}$ and

 $\vec{B}_l \ll \vec{B}_w$ are the magnetic field associated with the laser and the wiggler respectively,

For a transverse EM wave such as the laser beam,

$$\vec{B}_l = \vec{k} \times \vec{E}_l = \vec{z} \times \vec{E}_l$$

$m\frac{d(\gamma \vec{v})}{dt} = e\left[\vec{E}_l\left(1 - \beta_z\right) + \hat{z}\left(\vec{\beta} \bullet \vec{E}_l\right) + \vec{\beta} \times \vec{B}_w\right] + F_{reac}$

For

 $\beta_T \ll \beta_z \ll 1$

the laser field is not extremely strong the radiation loss (due to) is small compared to the electron energy

Conservation of canonical transverse momentum dictates

 $p_T = m \gamma V_T + e(A_l + A_w) = const$ Triveni Rao, USPAS 2008,

Annapolis

The longitudinal component describes the change in the energy of the electron and can be written as

$$mc^{2} \frac{d\gamma}{dt} = e\vec{v}_{T} \bullet \vec{E}_{l} - \frac{dP_{rad}}{dt}$$
$$\frac{dP}{dt} = \frac{2}{2} \frac{e^{2}}{2} \gamma^{6} \left[\vec{\beta}^{2} - (\vec{\beta} \times \dot{\beta})^{2}\right]$$

 \mathcal{U}





EM field can be assumed to be negligible and the radiated intensity per unit solid angle $d\Omega$ per unit frequency $d\omega$ can be expressed as

$$\frac{d^{2}I}{d\Omega d\omega} = \frac{e^{2}\omega^{2}}{4\pi^{2}c} \left| \int_{-\infty}^{+\infty} \vec{n} \times (\vec{n} \times \vec{\beta}) e^{i\omega\left(t-\vec{n} \cdot \frac{\vec{r}}{c}\right)} dt \right|^{2}$$

$$\lambda_l \approx \frac{\lambda_w}{2\lambda^2}$$

$$\lambda_{l} = \frac{\lambda_{w}}{2\gamma^{2}} \left(1 + \left(\frac{eB_{w}\lambda_{w}}{mc^{2}} \right)^{2} \right)$$

Intensity Spectrum is given by

$$I(\omega) \propto \left| \int_{0}^{N_{w}\lambda_{l}/c} e^{(-i(\omega-\omega_{l}))t} dt \right|^{2}$$

Line width is $\propto {N_w}^{-1}$

Linear Thomson scattering: Laser counter propagating to e beam

Assume the system to be the electrons moving in the EM field of the laser. The transverse field of the laser is equivalent to the wiggler with wiggler period equal to the periodicity of the laser (is the length of the one period of the wiggler). Since the laser and the electron beam are counter propagating, the wavelength of the scattered radiation in the forward direction (direction of motion of the electron) is now modified to

$$\lambda_l = \frac{\lambda_{laser}}{4\gamma^2}$$

The power radiated by a single electron interacting with the laser beam is

$$P_s = 21.3\gamma_0^2 \left(\frac{r_e}{r_0}\right)^2 P_0$$

- is the initial energy of the electron in units of its rest mass γ_0
- is the classical electron radius = $2.82*10-9 \mu m$ r_{e}
- is the spot size of the laser beam r_0
- $P_0(GW) = 21.5 \left(\frac{a_0 r_0}{\lambda_1}\right)^2$ $a_0 = \left| e \right| \frac{A_0}{m_0 c^2}$ is the normalized peak amplitude of the vector potential A_0 and is analogous to the wiggler strength parameter

Triveni Rao, USPAS 2008, Courtesy: P. Sprangle, A. Ting, E. Esare المجمع المجمع المجمع المجمع (1992).

The total radiated power in practical unit can be given as

$P_T(W) = 2.11$	$*10^{-2} \frac{L_0}{Z_R} \lambda_l (\mu m) I_b (A) E_b^{-2} (MeV) P_0 (GW)$
L_0	is the laser pulse length,
Z_R	is the Rayleigh length of the incident laser,
I _b	is the electron beam current in Amperes,
E_{b}	is the electron energy in MeV
P_0	is the laser power in GW

This radiation is emitted in a cone angle $\theta = \frac{1}{\gamma_0}$

The contribution to the spectral width of the radiation comes from three sources: the finite number of wiggler period $N_w = L_0 / \lambda_l$, emittance of the electron beam \mathcal{E}_b and the energy spread of the electron beam δE .

The total width can be written as

$$\left(\frac{\delta\omega}{\omega}\right)_{T} = \left(\frac{1}{N_{w}^{2}} + \frac{\varepsilon^{4}}{r_{b}^{4}} + 4\frac{\delta E^{2}}{E^{2}}\right)^{1/2}$$









e∹:

60 MeV, 0.5 nC, 140 A, 3.5 ps, 2 mm mrad, 32 μm spot

Laser:

10.6 μm, 600 MW, 180 ps, lin. Pol., 32 μm annular spot

Courtesy: I. Pogorelsky et al PHYSICAN, USPAS 2008, SPECIAL TOPICS – AB, VOLUME 3, 090702 (2000)



λ = 1.8 Åt = 3.5 ps n/pulse = 2.8*10⁷ n_{pk} = 8*10¹⁸

Terawatt Falcon Laser & Linac Photoinjector Laser Systems



on Scattering/







Nonlinear Thomson Scattering

When the strength of the laser field is large, nonlinear effects can be seen.

Laser strength parameter a₀ is defined as

 $a_0 = eA_0/m_ec^2$

= $0.85*10^{-9*}\lambda(\mu m)*\sqrt{I_0(W/cm^2)}$

 $a_0 << 1$:Linear Thomson scattering: radiation at fundamental frequency $a_0 \approx 1$, Nonlinear Thomson scattering: radiation at harmonic frequencies



Courtesy: M. Babzein et al. Phys. Rev. Lett. 96, 54802 (2006)



FIG. 2 (color). Simulated energy spectra of Thomson x rays. Solid lines: (black line) at the interaction point; (red line) on the detector after attenuation in the Be window and air; (blue line) filtered by a 10 μ m Ag foil. Dashed lines show combined spectral transmission of the Be window with air (red line) and Ag foil (blue line). A green line shows the high-energy edge (6.5 keV) for the linear memory spectral spectral spectral transmission.

Annapolis





(a)

(b)

FIG. 3 (color). X-ray images observed on a luminescent screen: (a) without the Ag foil, and (b) with the 10 μ m Ag foil filter.

Advantages of Thomson scattering: Mono-energetic: no need for spectrometer Tunable with laser wavelength and electron beam energy High Brightness Short pulse Lower electron energy

Disadvantage: Typically lower repetition rate: average photon flux Multiple interactions to increase the repetition rate

Laser Wire for e beam diagnostics



Triveni Rao, USPAS 2008,

Courtesy: http://www.hep.ph.rhul.ac.uk/~kamps/lbbd/welcome.html#ScientificCase

Linear Thomson Scattering: Laser propagating transverse to e- Beam

Similar to counter propagating, but \succ Wavelength of the emitted radiation is *2 Number of interacting electrons and photons is low Low signal- may be as low as 10⁻³ per interaction Need very high power laser •Need large electron density Highly optimized laser transport

Triveni Rao, USPAS 2008,

Courtesy: http://www.slac.stanford.edu/cgi-wrap/getdoc/slac-pub-8057.pdf

Laser Beam intensity:

Let the laser beam with Gaussian profile propagate along z. The intensity at (x, y, z) is

$$I_{l}(x, y, z) = I_{l,0}e^{-\left[\frac{(x-x_{l})^{2}}{\omega^{2}(z-z_{l})} + \frac{(y-y_{l})^{2}}{\omega^{2}(z-z_{l})}\right]}\left[\frac{\omega_{0}}{\omega(z-z_{l})}\right]^{2}$$

 $I_{I,0}$ is a constant and the waist ω_0 is at x_I, y_I, z_I

Total laser intensity is given by

$$I_{l,tot} = \pi \omega_0^2 I_{l,0}$$

Electron Beam Intensity

In the same coordinate system, the intensity of electron beam with a Gaussian distribution can be written as

$$I_e(x, y, z) = I_{b,0}e^{-\left[\frac{(x-x_b)^2}{\sigma_x^2} + \frac{(y-y_b)^2}{\sigma_y^2} + \frac{(z-z_b)^2}{\sigma_z^2}\right]}$$

 $I_{b,0}$ is a constant, (x_b, y_b, z_b) is the center of the electron beam and σ_x , σ_y , and σ_z its size along x,y,and z respectively

Total electron beam intensity is

$$I_{b,tot} = \pi^{3/2} \sigma_x \sigma_y \sigma_z I_{b,0}$$

Nicolas Delerue, University of Oxford Criveni Rao, USPAS 2009colas.delerue.org Annapolis http://www-pnp.physics.ox.ac.uk/~delerue/

Beams Overlap

$$N_{tot} = I_{l,0}I_{b,0} \times$$

$$\int \left[\frac{\omega_0}{\omega(z-z_l)}\right]^2 e^{-\frac{(x_l-x_b)^2}{\omega^2(z-z_l)+\sigma_x^2}} \sqrt{\pi \left[\frac{\sigma_x^2 \omega^2(z-z_l)}{\sigma_x^2+\omega^2(z-z_l)}\right]^2}$$

$$\times e^{\frac{(y_l - y_b)^2}{\omega^2(z - z_l) + {\sigma_y}^2}}$$

$$\pi \left[\frac{\sigma_y^2 \omega^2 (z - z_l)}{\sigma_y^2 + \omega^2 (z - z_l)} \right]$$

 $-z_l$)

 \times

 $e^{-\left[\frac{(z-z_b)^2}{\sigma_z^2}\right]}dz$

$$N_{tot} = \pi^{3/2} I_{l,0} I_{b,0} \sigma_x \sigma_y \sigma_z \omega_0^2 \times \frac{(x_l - x_b)^2 \times (y_l - y_b)^2}{\left[\omega^2 (z_b - z_l) + \sigma_x^2\right] \times \left[\omega^2 (z_b - z_l) + \sigma_y^2\right]}$$

$$e^{-\left[\omega^2 (z_b - z_l) + \sigma_x^2\right] \times \left[\omega^2 (z_b - z_l) + \sigma_y^2\right]}$$

 ι

U

Triveni Rao, USPAS 2008, Annapolis

 $\boldsymbol{\mathcal{D}}$

 ι

Machine	sigma x microns	sigma y microns	Required Wavelength: microns
TESLA (Diagnostic section 250GeV)	120um	7um	0.67 um
JLC 500GeV	10	3	1.3 um
NLC 500GeV	10	1.25	0.22 um
NLC 1TeV	7.5	0.9	0.15 um

 Wavelength: Significantly smaller than the e spot size Minimum laser spot size set by diffraction limit
 Power: Tens of MW Efficiency ~10⁻³
 Laser transport: Spot size diffraction limit Rayleigh length > other transverse dimension
 Damage threshold Triveni Rao, USPAS 2008, Annapolis

Typical Issue

- The laser beam has a diameter of several millimeters.
- We want a wire size of only a [few] micrometers
- The laser light must be focused by wide aperture lens.
- No commercial lens seems to suits our needs
 => Custom design

Courtesy

Nicolas Delerue, Universityอย่ Raod USPAS 2008, http://www-pnp.physics.ox.ac.uk/~dcAกคลpolis

- Goal: concentrate as much energy as possible in the smallest possible radius (gives the best performance).
- As the laser beam will be scanned across the lens, the size of the spot must remain constant over the scanning range.
- As the lens will be used with a high power laser, it must have no first order ghosts and as few second order ghosts as possible.
- To facilitate the alignment of the lens, aberrations must be kept as low as possible.
- Effect of a tilt of one element of the lens with respect to the others must be studied carefully



Triveni Rao, USPAS 2008,

Annapolis Courtesy: P. Tenenbaum, T. Shintake, SLAC Pub 8057



Signal from Laser wire. $\lambda = 350$ nm, spot size 1µm, power10 MW